

Closed



RECEIVED
MAR 0 1998

(4/5)

Certificate of Compliance

Certificate Number: LR 24825-130

Revision: LR 24825-157

Date Issued: February 25, 1998

Issued To: **Omron Electronics Inc.**
One E. Commerce Dr.
Schaumburg, IL 60173
USA
Attention: Mr. J. Zielinski

P.O.# 97K5011

The products listed below are eligible to bear the CSA Mark.

**NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*

Issued By: J. Lam, C.E.T.
Toronto, ON, Canada

Signature

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus
3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - CERTIFIED TO U.S. STANDARDS

PRODUCTS

Relays, Type G6S (with suffixes), open type with dust cover, 2-pole, NO or NC, max ratings: 0.5A, 125V ac general use, 0.3A, 110V dc resistive, 2A, 30V dc resistive, coils: 1.5 through 48V dc.

APPLICABLE REQUIREMENTS

- | | | |
|-------------------|--------|---|
| CAN/CSA-C22.2 No. | 14-95 | - Industrial Control Equipment |
| CAN/CSA-C22.2 No. | 950-93 | - Safety of Information Technology Equipment, Including Electrical Business Equipment |
| UL Std No. | 1950 | - Information Technology Equipment Including Electrical Business Equipment |
| UL Std No. | 508 | - Industrial Control Equipment |

The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.