



MAR 6 1998

# Certificate of Compliance

Certificate Number: LR 15734-297A

Revision: LR 15734-420A

Date Issued: February 27, 1998

Issued To: SIEMENS ELECTROMECHANICAL COMPONENTS,  
INC.  
200 S. Richland Creek Dr.  
Princeton, IN 47671-0001  
Attention: Ms. Janice McGillem

*The products listed below are eligible to bear the CSA Mark.*

*\*NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*

Issued By: A. Zemanek, P. Eng.  
Toronto, ON Canada

Signature

## CLASS

3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic  
3211 84 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic - CERTIFIED TO U.S.  
STANDARDS

## PRODUCTS

Relays, Type 92 (with suffixes), open type with dust cover, double pole, single throw and double throw contacts, coil rated 110V dc max and 277V ac max, 60Hz or 50/60Hz or 50Hz, contacts rated as per report.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-M91  
UL Std No. 508

Industrial Control Equipment  
Industrial Control Equipment

\* The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.